

CERTIFICATE OF COMPLIANCE

Certificate Number 20170221-E10514
Report Reference E10514-19970225
Issue Date 2017-February-21

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
3940 MARTIN LUTHER KING DR
ST LOUIS MO 63113

This is to certify that representative samples of CONDUIT FITTINGS FOR USE IN HAZARDOUS LOCATIONS
SEE ADDENDUM PAGE FOR MODELS

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: Standard No. UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations,
Standard No. CAN/CSA C22.2 No. 25-1966, Enclosures for Use in Class II Groups E, F, and G Hazardous Locations,
Standard No. CAN/CSA C22.2 No. 30-M1986, Issued 1986-11 + General Instruction No. 2:1988-11, Explosion-Proof Enclosures for Use in Class I Hazardous Locations,

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20170221-E10514
Report Reference E10514-19970225
Issue Date 2017-February-21

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL – Fittings for use in Hazardous Locations, Class I, Groups A, B, C and D; Class II, Groups E, F, and G.

Conduit elbows (90° bend), Cat. Nos. BL-90-1 and BL-90-1M, conduit size 1/2 in.; BL-90-2 and BL-90-2M, conduit size 3/4 in.; Cat. Nos. BL-90-3 and BLF-90-3 conduit sizes 1 in.

USL - Fittings for use in Hazardous Locations, Class I, Groups C and D; Class II, Groups E, F, and G.

Conduit elbow (90° bend), Cat. No. BL-90-4, conduit size 1-1/4 in., Cat. No. BL-90-3M conduit sizes 1 in., Cat. Nos. BLF-90-4, conduit size 1-1/4 in.

USL – Fittings for use in Hazardous Locations, Class I, Groups B, C and D; Class II, Groups E, F, and G.

Short radius capped elbows (90° bend), Cat. Nos. Y-1 to Y-5 inclusive, conduit sizes 1/2, 3/4, 1, 1-1/4 and 1-1/2 in.

USL, CNL – Fittings for use in Hazardous Location, Class I, Groups B, C and D; Class II, Groups E, F and G Hazardous Locations.

Short radius capped elbows (90° bend), Cat. Nos. Y-1M to -5M inclusive, conduit sizes 1/2, 3/4, 1, 1-1/4 and 1-1/2 in. for use in Class I, Groups B, C and D; Class II, Groups E, F and G Hazardous Locations.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

